



Office of the Station Officer
Fire and Rescue Station
Thiruvananthapuram-01

NO: C.807/2020

Date: 24 August 2020

SAFETY CERTIFICATE

As per the request of Rev Fr Chacko Thekkemary John, Lourdes Mount Public School, Kankkode, Vattappara P O, Thiruvananthapuram-28 vide letter dated 24 August 2020, I have inspected the firefighting arrangements provided in the Educational Building with G+2, a height of 9.75 M, Plint Area: 2087.82 SQM Re survey Number 508 in Nedumangadu Taluk, Vembayam Village, Block No:32, and found the Following arrangements.

1. Fire Extinguisher
2. Hose Reel
3. Down Comer
4. Booster Pump 900 LPM
5. Fire Brigade Inlet
6. Over Head Tank 15000Ltr capacity

The above arrangements were tested and were found working satisfactorily at the time of Inspection.



Station Officer
Fire and Rescue Station
Thiruvananthapuram

Mariam

[Signature]
MANAGER
LOURDES MOUNT PUBLIC SCHOOL
VATTAPPARA, TVPM- 28, KERALA



PRINCIPAL
LOURDES MOUNT PUBLIC SCHOOL
Vattappara, Thiruvananthapuram-28
Kerala, School Code: 75779
E-mail: lourdescbse@yahoo.com